

**Jeanne Guthrie**

---

**From:** Zachary Ward <zward@sherbornfire.com>  
**Sent:** Tuesday, January 07, 2025 9:24 PM  
**To:** Jeanne Guthrie  
**Subject:** Re: Brush Hill Homes Updated Plan of Four Single Family Homes -- 12 bedrooms

Hi Jeanne:

The developer, Mr. Murchison, requested documentation stating that we communicated about this and that the Fire Department is approving this design in regard to access to the site. Please let this email confirm that the Fire Department does approve of this design.

Originally submitted with smaller access roads, we worked with the developer and he agreed to meet our needs.

This approval is contingent on two items:

1. The developer putting in a 20,000-gallon water tank for firefighting, which he has agreed to do and is shown on one of these plans.
2. The developer agreeing to submit to the fire department a "truck turn plan", which he has also agreed to do.

Please let me know if you need anything else from me.

**Chief Zachary J. Ward**  
**Sherborn Fire & Rescue**  
22 North Main Street  
Sherborn, MA 01770  
Office: (508)653-3270

