



January 8, 2025

Mr. Zachary McBride, Chair
Sherborn Zoning Board of Appeals
Town Hall
19 Washington Street
Sherborn, MA 01770

**Re: Brush Hill Homes Residential Development – Comprehensive Permit
Engineering Peer Review – Site/Civil
34 Brush Hill Road
Sherborn, Massachusetts**

Dear Mr. McBride:

Tetra Tech (TT) has reviewed specific submittal materials for the above-referenced Project to assist the Sherborn Zoning Board of Appeals (Board) in its Comprehensive Permit review of the proposed Brush Hill Homes development. The Applicant has revised the Project scope which has decreased the number of units and changed roadway layout. The following letter provides comments generated during our review of Applicant submittals and generally focus on substantive concerns that speak to issues whose eventual resolution may substantially impact Project design or could otherwise result in potentially unsafe conditions or unanticipated impacts.

The modified Project includes development of four single-family housing units on approximately 5.1 acres of land with a lot shape commonly referred to as a “flag lot”. The site is accessed from Brush Hill Road through an approximate 500-foot by 50-foot strip of land which is bounded by two existing residential lots fronting on Brush Hill Road. The developable portion of the lot is located at the rear of the two abutting residential properties. The remaining site is bordered by Sherborn conservation land to the north and east. The site is currently wooded with an adjacent vegetated wetland in the northeast portion of the site. Each unit is proposed with a driveway but visitor parking has been removed from the Project scope as part of the modification. Each unit will be served by its own private well and all units are connected to an on-site shared septic system. A typical curb and gutter stormwater system is proposed to capture runoff from the Project, stormwater basins have been removed from the Project scope as part of the modification.

Our review is based on materials received from the Board comprising the following pertinent documents:

- A Cover Letter dated December 23, 2024, prepared by DGT Associates Surveying & Engineering (DGT).
- A plan set (Plans) titled "Permit Site Plan for Brush Hill Homes at 34 Brush Hill Road in Sherborn, MA", dated June 4, 2024 with revisions through December 23, 2024, prepared by DGT.
- A plan set (Plans) titled "Brush Hill Homes, Subsurface Sewage Disposal System Plan", dated June 26, 2024 with revisions through December 23, 2024, prepared by DGT.
- Septic system pump design calculations titled "Pump Design Calculations for the Brush Hill Homes at 34 Brush Hill Road in Sherborn, Massachusetts 01770", dated December 23, 2024, prepared by DGT.

The Plans and accompanying materials were reviewed for good engineering practice, overall site plan efficiency, stormwater, utilities and public safety as it relates to each of the subject areas. Our initial comments are provided below.

A. SITE DESIGN

The Site Plans provide a good introduction to the scope of the Project and its various components. The proposed dwellings are accessed through a 19-foot-wide access roadway which terminates at a hammerhead configuration, each leg of the hammerhead is 17-feet wide and approximately 200 feet in length and run parallel to the abutters'

Infrastructure Northeast

Marlborough Technology Park 100 Nickerson Road, Marlborough, MA 01752

Tel 508.786.2200 Fax 508.786.2201 tetratech.com

rear property lines. Two dwellings are located on each of the hammerhead roadways. The following specific comments are offered to identify areas where additional information is required, or changes are requested to address questions or support further review.

- A.1. A roadway profile and cross-section should be included in the Plans.
- A.2. The main access roadway is proposed at 19 feet in width and approximately 500 feet in length without secondary access. Each hammerhead roadway is proposed at 17 feet in width and approximately 200 feet in length with no proposed turnaround area. We recommend the Applicant provide written confirmation from the Sherborn Fire & Rescue Department related to their review of the Project.
- A.3. The Applicant has decreased the width of the proposed roadway to 19 feet. We recommend on-street parking be prohibited along each of the access roadways so site access and circulation is not impeded.
- A.4. The Applicant should detail areas for snow storage. Each leg of the hammerhead roadway is within five feet of the abutting property line and plowed snow shall be contained on the subject property.
- A.5. A Landscape Plan has not been provided. The Applicant should confirm if landscaping is proposed for the Project to screen the Project from abutting residences.
- A.6. A detail of the proposed retaining walls should be provided on the Plans. The proposed walls are greater than four feet in height which will require structural design and approval by the Building Department.
- A.7. Project scope is proposed within jurisdiction of the Massachusetts Wetlands Protection Act (WPA). Permitting with the Sherborn Conservation Commission is expected.

B. STORMWATER

Modified Project scope includes development of four units of housing clustered on approximately 5.1 acres of land. Stormwater runoff generated by the Project is captured by traditional piped infrastructure and discharged via flared end section to the existing wooded area to remain on the north end of the subject property. Stormwater basins have been removed from the Project scope. As noted, the Project includes development of four single-family housing units and does not appear to discharge to a critical area which does not require compliance with the Massachusetts Department of Environmental Protection (MA DEP) Stormwater Management Standards (Standards) and Stormwater Handbook (Handbook).

The following comments are offered specific to the Project Stormwater design.

- B.1 Although compliance with the MA DEP Standards and Handbook is not required, it is rare that a development Project not include peak runoff mitigation/water quality treatment particularly with the recognized challenges of climate change and effect of development on water quality. We recommend the Applicant consider providing stormwater mitigation measures and/or low impact development (LID) techniques in the Project scope. Additionally, we recommend a Long-Term Pollution Prevention Plan (LTPPP) and Long-Term Operation and Maintenance Plan (O&M Plan) be developed to identify and manage potential pollutant sources and provide guidance on inspection and maintenance of proposed stormwater infrastructure and roadway.
- B.2 The Project appears to meet the requirements for coverage under the US EPA NPDES General Permit for Discharges from Construction Activities (CGP). We recommend a Condition requiring the Applicant provide proof of coverage under the NPDES CGP and provide a copy of the approved Stormwater Pollution Prevention Plan (SWPPP) prior to construction.
- B.3 We recommend catch basins be proposed in the main site roadway immediately upgradient of the hammerhead intersection (at approx. roadway elev. 225) to capture runoff prior to flowing through the intersection.

B.4 We recommend the Applicant provide pipe, grate sizing and spread calculations to ensure the stormwater system is able to effectively capture and convey runoff. Special care should be given to the entrance roadway and its 6% slope to ensure runoff is captured and does not bypass structures during heavier rain events which may cause flooding in the downgradient areas. Cascade grates are recommended along the entrance roadway. Additionally, the Applicant is proposing 10-inch HDPE drain pipe, minimum pipe diameter is commonly 12-inches for roadways.

C. EROSION AND SEDIMENTATION CONTROL

The Applicant has included provisions for erosion and sediment control as part of the Project scope. Additionally, the Project is covered under the NPDES CGP and we anticipate additional information related to erosion and sediment control will be available prior to construction. The following comments are offered specific to the Project and potential for off-site erosion during construction.

C.1 The Applicant should provide earthwork calculations on the Plans to assist reviewers and the public in understanding the size and scale of earthwork operations for the Project. Additionally, a Construction Management Plan is recommended to detail truck travel routes, project phasing, hours of operation, equipment laydown areas, stockpile locations, etc.

C.2 The Applicant is not proposing any temporary sediment basins to mitigate runoff during construction. The existing site is consistently sloped at approximately 10% and mapped as a hydrologic soil group (HSG) C which have a moderate runoff potential.

D. WATER SUPPLY

The Plans indicate the Project will be served by two private water supply wells which will each serve two of the proposed units. The Project proposes a total of 12 bedrooms with a potential resident count of 24 people which is below the 25 person threshold for Public Water Supply designation. The following comments are offered specific to Project water supply and related analysis or lack thereof.

D.1 The Applicant should provide information related to the ownership of the private wells.

E. SEWER/SEPTIC SYSTEM

The Plans indicate the Project will be served by a shared Soil Absorption System (SAS) receiving flow from a standard gravity system (Units #1 & #2) and force main system (Units #3 and #4) to collect and treat sewerage generated from the Project. The Septic System scope was reviewed against the Massachusetts Department of Environmental Protection (MA DEP) State Environmental Code, Title 5 (310 CMR 15) (Title 5). The Project was also reviewed for general sewer/septic system design elements and good engineering practice. The following comments are offered specific to Project septic design and related analysis or lack thereof.

E.1 The design of the Soil Absorption System (SAS) appears to meet the requirements of Title 5.

E.2 Test pits generally indicate a substrate of firm sandy loam to depths of over ten feet. ESHGW was determined by soil mottles (the most accurate method) at a relatively consistent depth of between 31 and 38 inches below the surface. Soil conditions and infiltration rates (by percolation test) meet the requirements of Title 5.

E.3 The site is located in a Title 5 nitrogen sensitive area due to the proposed on-site water supply. The MA DEP nitrogen loading limitations allow 440 gallons per day of standard septic discharge per acre. The Project Site is 5.57 Title 5 acres (40,000 square feet/acre). Therefore, the maximum allowable Title 5 nitrogen discharge for the site is 2,450 gallons per day. The proposed Title 5 discharge rate for the Project is 1,320 gallons per day (12 bedrooms) which is within the allowable Title 5 limit.

E.4 Title 5 can require groundwater mounding analysis for SAS areas discharging over 2,000 gallons per day. However, mounding analysis is not required on this Project as the SAS discharges 1,320 gallons per day.

E.5 The proposed soil absorption system (SAS) is located 10 feet from the foundation of Unit #1 and #2 which may include basements/foundation drains. Foundation drains may intercept effluent from the

Brush Hill Homes Residential Development – Comprehensive Permit
Engineering Peer Review – Site/Civil
January 8, 2025 Review Letter

SAS (Trench #1 and #2) and convey to daylight. The Applicant shall confirm if basements are proposed in the units and if foundation drains will be required by code and if so, appropriate setbacks that meet Title V shall be provided.

These comments are offered as guides for use during the Town's review and additional comments are likely to be generated during the course of review. The Applicant shall be advised that any absence of comment shall not relieve him/her of the responsibility to comply with all applicable local, state and federal regulations for the Project. If you have any questions or comments, please feel free to contact us at (508) 786-2200.

Very truly yours,



Steven M. Bouley, PE
Project Manager
(Site/Civil Review)



Peter Dillon, PG
Geoscience Discipline Lead
(Water Supply/Septic Review)

P:\323009\143-323009-24002 (ZBA BRUSH HILL HOMES)\DOCS\BRUSH HILL HOMES-ZBAREV(2025-01-08)_SITE.DOCX