

Lab. ID # 118418

To: Town of Sherborn 19 Washington St. Sherborn, MA 01770
--

Received Date/Time:	7/28/25, 1:30 PM
Analyzed Date/Time:	7/28/25, 2:20 PM
Reported Date:	7/29/25
Collected By:	G & L Labs.
Collection Date:	7/28/25

ANALYTICAL RESULTS

Sample#	Sampling Location	Sampling Time	E. coli (CFU/100mL)
1	Farm Pond	11:15 AM	8
Maximum Contaminant Level			235
Method of Reference			EPA 1603.1

Laboratory QC Results

QC	Unit	E. coli
Duplicate (D1)	CFU/100mL	8
Duplicate (D2)	CFU/100mL	5
Log Dif. of Dup		0.2041
MS Recovery	%	80%
MS Rec. Criteria	%	17%-117%
Dilution Blk.(Beginning)	CFU/100mL	Negative
Dilution Blk.(Ending)	CFU/100mL	Negative
Positive Control	CFU/100mL	Positive

Approved By:


 Lab. Director

Date

7/29/25

