

§ 305-2.16. Pipes and equipment.

- A. All service pipes and connections shall be of nontoxic materials and meet the specifications the current version of NSF/ANSI 61-2021 Drinking Water System Components — Health Effects.
- B. The installation of pipes shall be such that they are protected from crushing, freezing and/or attack by animals or rodents.
- C. Dissimilar metals should be discouraged in the water system. The use of nonconductive plastic inserts between pipes and fittings or the installation of sacrificial anodes is helpful in minimizing electric corrosion problems.
- D. Electrical service grounds shall not be attached to water piping. All electrical service and controls of the well must be permitted, inspected and approved according to Town and state regulations.