

**§ 305-2.11. Well specifications.**

- A. Well yield. There shall be a minimum yield of 300 gallons per bedroom per day at 20 pounds per square inch (psi) at the highest fixture serviced. System capacity for semipublic water supplies must be adequate to meet the projected needs.
- B. Storage. All demands for water shall be provided from storage in a pressure tank. Pressure tanks for individual home installations shall be of a diaphragm type and have a minimum capacity of 36 gallons. Pressure tanks may be installed in series to meet storage volume requirements.
- C. Well installation and development. Wells shall be installed and developed in accordance with Sherborn-specific regulations and MassDEP's current Private Well Guidelines.
- D. Static water level. If the static water level in a well is shallower than the depth to bedrock for the well boring once development of the well is completed, the licensed well driller shall determine the reason(s) for the level and provide a written statement to the Board of Health regarding whether the well is inappropriately drawing from overburden groundwater and requires corrective action.